

Date: 11.08.2022

PROOF OF CONFIRMITY (POC) TESTING GREENTECH FUEL ENHANCER ON GENERATOR

Greentech Fuel Enhancer & Emission Control Device was installed on KIRLOSKAR 45 KVA Generator for testing FUEL EFFICIENCY & EMISSION REDUCTION.

GREENTECH FUEL ENHANCER RESULTS					
GENERATOR MODEL - KIRLOSKAR 45 KVA					
READINGS IN NORMAL MODE			BRANCH - SHAHPUR		
SL NO	MONTH	DIESEL AMOUNT	TOTAL LTRS CONSUMED	TOTAL HRS	AVG IN LTRS PER HOUR
1	Jan-22	10000.00	117.04	37.39	3.13024873
2	Feb-22	10000.00	117.04	34.5	3.392463768
3	Mar-22	14000.00	162.35	33.58	4.834723049
4	Apr-22	4000.00	42.65	9	4.738888889
	TOTAL	38000.00	439.08	114.47	3.835764829

READINGS WITH GREENTECH FUEL ENHANCER INSTALLED ON 07/04/2022					
SL NO	MONTH	DIESEL AMOUNT	TOTAL LTRS CONSUMED	TOTAL HRS	AVG IN LTRS PER HOUR
1	Apr-22	8000.00	85.3	19.23	4.435777431
2	May-22	12000.00	127.89	44.52	2.872641509
3	Jun-22	13000.00	147.2	37.28	3.948497854
4	Jul-22	14000.00	123.33	41.29	2.986921773
	TOTAL	47000.00	483.72	142.32	3.398819562

FUEL SAVED & CO2 REDUCED WITH GREENTECH					
	DIFFERENCE IN AVG LTRS/HOUR	% OF FUEL SAVED	NO OF LTRS SAVED	AMOUNT SAVED@Rs.87	TOTAL CO2 REDUCED IN KGS
	0.44	11.46	62.79	5463.00	165.77



CONCLUSION: GREENTECH FUEL ENHANCER & EMISSION CONTROL DEVICE HAS SAVED 11.46% OF Fuel AND REDUCED CARBON EMISSIONS BY 167.55 kgs.



Date: 11.08.2022

PROOF OF CONFIRMITY (POC) TESTING GREENTECH FUEL ENHANCER ON GENERATOR

Greentech Fuel Enhancer & Emission Control Device was installed on KIRLOSKAR 45 KVA Generator for testing FUEL EFFICIENCY & EMISSION REDUCTION.


GREENTECH FUEL ENHANCER RESULTS					
GENERATOR MODEL - KIRLOSKAR 45 KVA					
READINGS IN NORMAL MODE			BRANCH - KOPPAL		
SL NO	MONTH	DIESEL AMOUNT	TOTAL LTRS CONSUMED	TOTAL HRS	AVG IN LTRS PER HOUR
1	Jan-22	12000.00	139.79	26	5.376538462
2	Feb-22	6000.00	69.89	16	4.368125
3	Mar-22	10000.00	115.46	26	4.440769231
4	Apr-22	2000.00	30	6	5
TOTAL		30000.00	355.14	74	4.799189189

READINGS WITH GREENTECH FUEL ENHANCER INSTALLED ON 07/04/2022					
SL NO	MONTH	DIESEL AMOUNT	TOTAL LTRS CONSUMED	TOTAL HRS	AVG IN LTRS PER HOUR
1	Apr-22	8000.00	74.61	22	3.391363636
2	May-22	12000.00	125.64	34	3.695294118
3	Jun-22	8000.00	90.2	22	4.1
4	Jul-22	7790.00	78.21	23	3.400434783
TOTAL		35790.00	368.66	101	3.65009901

FUEL SAVED & CO2 REDUCED WITH GREENTECH					
	DIFFERENCE IN AVG LTRS/HOUR	% OF FUEL SAVED	NO OF LTRS SAVED	AMOUNT SAVED@Rs.87	TOTAL CO2 REDUCED IN KGS
	1.15	23.96	116.14	10104.18	306.61



CONCLUSION: GREENTECH FUEL ENHANCER & EMISSION CONTROL DEVICE HAS SAVED **23.96%** OF Fuel AND REDUCED CARBON EMISSIONS BY 167.55 kgs.



For **GOODWILL AUTO'S**

Managing Partner.